

## Request for Tender – Gravel (A+B)

### 2022-04 Addendum #1

**Q#1:** On Schedule 'B' under General Note it states that layer thickness shall be 65mm (2.5") is this correct?

**A#1:** No. Schedule 'B' under General Note it should state that layer thickness shall be 76mm (3")

Schedule 1: Locations and Quantities

ROAD NAME	MATERIAL	FROM		TO	NOTE	SECTION	LENGTH (km)	TONNES Gran B	TONNES Gran A
<b>1. SUPPLY AND APPLY</b>									
Nipissing Road South	Gran. A	Wolf Lake	South to	Rock Hill Road Orange Valley Road		1345	1.2		1,301
		Rock Hill Road	South to			1340	1.5		1,626
Orange Valley Road	Gran. A	Nipissing Road South	to	2nd Bridge		1470	3.4		3,687
Pearceley Road	Gran. A	Hwy 124	to	Grindstone Road		1490	0.8		868
Horner Road	Gran. A	Hwy 520	to	End		970	1.2		1,301
Chapman Drive East & West	Gran.A	Hwy 520	to	Hwy 520		480	2.6		2,819
<b>2. STOCKPILE</b>									
Stock Pile	Gran. A								2,500
<b>3. STOCKPILE</b>									
Stock Pile (18 Miller Rd Yard)	Gran. B							1,000	
<b>Totals</b>							<b>10.7</b>	<b>1,000</b>	<b>14,102</b>

General Note: Unless otherwise noted, layer thickness shall be 76mm (3").

General Note: Pre Site Meeting With Grader Operator to Confirm Locations Required