



Municipality of Magnetawan

Public Works Contract #: RFP 2025-05

REPLACEMENT OF BRIDGE #17 – MILLER ROAD

DATE: September 8th , 2025

ADDENDUM #3 - FINAL

This addendum will become part of the Public Works Contract #: RFP 2025-05

Questions Received

Q1. It has been brought to our attention that there is a discrepancy on the rock socket length of the piles for the new abutments. The section shows 0.5m whereas #5 under the additional general structural notes says 1.8m. Could you please kindly confirm which is correct.

R1 The rock socket should be 1.8 m deep.

(A signed copy of this addendum must be included in Tender submission.)

I /WE hereby acknowledge receipt of this addendum.

(Signature of Contractor)

(Company Name)

PLEASE SIGN AND INSERT WITH TENDER SUBMISSION