

## **Request for Tender – Gravel (A+B)**

### **RFT 2025-01 Addendum #1**

---

**Q#1:** Section 2.02 states... where the total thickness of crushed material called for in the Schedule exceeds 100mm thickness, it shall be placed in multiple layers. Each layer shall not exceed 100mm in thickness. Beaver Lake Road calls for 10.16 cm/ 101.6 mm depth. Can you confirm that this requires two separate lifts/passes to achieve the 101.6 mm depth?

**A#1:** Given the rural location of Beaver Lake Road only one (1) pass is required to achieve the 101.6 mm depth.