



Planners | Surveyors | Biologists | Engineers

October 2, 2026
Contract No.: RFT-2026-02

ADDENDUM #2

Two (2) Pages

Bay Street Temporary Bridge Installation
Tender Number: RFT-2026-02

Please find enclosed Addendum No. 2 for the above noted Contract. Confirmation that this addendum has been received shall be indicated in your tender submission under the Tender Form Section - Statement "E" – Addenda in the Tender Form.

Please treat this as an original. No follow up copy will be provided.

TULLOCH ENGINEERING INC.

Frank Palmay, P.Eng.
Structural Engineering Lead
frank.palmay@tulloch.ca

ADDENDUM #2

Bay Street Temporary Bridge Installation

Issue Date: October 2, 2026

This addendum is issued for the purpose of clarifying, amending, or revising certain information contained in the Contract Documents. This Addendum No. 2 shall form an integral part of the Contract Documents.

Clarifications

All tender documents can be found at the Township's website at the following link: [RFT 2026-02 Bay Street Bridge Installation - Municipality of Magnetawan](#).

Questions & Answers:

Question 1: Bridge length is noted as 50' on drawing S1 and 60' in Addendum 1 please clarify

Answer 1: Bridge length is per drawing S1 50' please disregard Q4 and A4 in Addendum 1

Question 2: Typical bearing pad widths are 300 mm Q1 A1 in Addendum 1 notes bearing pad to be 400 mm wide please confirm

Answer 2: Bearing pads shall be 300 mm wide disregard Q1 and A1 in Addendum 1.

END OF ADDENDUM #2