

Request for Proposal – Surface Treatment

(Double Lift Tar & Chip)

RFP 2026-02 Addendum #4

Q#1: Can you clarify the quantity of grade work required - contract states 10,500m² but 1500m x 8m should equal 12,000m²?

A#1: Estimated as wider

Q#2 What type of emulsion will be used for the tar & chip?

A#2 HF150S

Q#3: What type of Aggregates will be used for the tar & chip??

A#3 Class 2 (Quarried)

Q#4: Can the township clarify who will be in charge of the fine grade prior to the tar & chip application in 2027?

A#4: Contractor of the winning bid

Q#5: Page 7 States the Municipality requires an estimated 40,000m² of surface treatment, but the tender looks like you are only asking for pricing on 10,500m²? Are you able to confirm if more roads will be provided?

A#5: It is a misprint – the Municipality requires 10,500m²