

**Fire Protection Survey Services™**

2403 Fairgrounds Road  
Washago, Ontario, Canada, L0K 2B0  
Telephone: (249) 359-7231  
E-mail: [fpss@xplornet.ca](mailto:fpss@xplornet.ca) Website: [www.fpss.ca](http://www.fpss.ca)

**Fire Department Water Tanker Shuttle Accreditation**

Presented To: **Municipality of Magnetawan**

**ACCREDITED FIRE STATIONS**

**Magnetawan Fire Station**

**Ahmic Harbour Fire Station**

**Date Test Passed: August 22nd, 2018**

**Flow Achieved: 225 I.G.P.M. 1020 LITERS/MIN.**

**Two (2) Hour Test Time**



Signed: Peter J. Rose

Peter J. Rose, C.E.T., F.P.T.  
Senior Partner  
Senior Fire Protection Specialist  
Senior Loss Control Specialist

**This Certificate Expires on September 1, 2023**

Please refer to the website for confirmation. The following information has been copied from the website.

Department Water Tanker Shuttle Accreditation

Fire Protection Survey Services

2403 Fairgrounds Road

Washago, Ontario, Canada, L0K 2B0

Telephone 249-359-7231

E-mail [fpss@xplornet.ca](mailto:fpss@xplornet.ca) Website: [www.fpss.ca](http://www.fpss.ca)

NOTE: This accreditation is only valid within 8 km of the fire station for dwellings and 5 km for commercial properties, unless the underwriting insurance company deems differently

ALL FIRE STATIONS, LISTED BELOW, ARE A COMMERCIAL / INDUSTRIAL FIRE PROTECTION CLASSIFICATION 9, UNLESS SHOWN OTHERWISE IN BRACKETS AFTER THE FIRE STATION NAME.

**Magnetawan, Municipality of**

**Magnetawan F.S.**

**81 Albert Street Magnetawan Village**

**Ahmic Harbour F.S.**

**60 Ahmic Street Hamlet of Ahmic Harbour**

**Accreditation Test Passed August 22, 2018**

Document Copied from Website, with Permission from FPSS